



RAdata, LLC  
 27 Ironia Road, Unit 2  
 Flanders, NJ 07836  
 973-927-7303 Phone  
 973-927-4980 Fax

**Customer:** Felician School  
 260 South Main Street  
 Lodi, NJ 076440000

## Laboratory Results

**Sample Number** 0325-4328  
**Sample Location** 260 South Main Street - Lodi Boro  
**Collected By** Ken, Waldele

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0325-4328	3/27/2025 7:38:00 AM Ground Floor Boys Room Sink	4/1/2025 9:11:00 AM	Lead (1st Draw)	4.92 ug/L	15 ug/L 2 ug/l	Std Method 3113B
0325-4328-1	3/27/2025 7:38:00 AM Ground Floor Boys Room Sink	4/4/2025 1:56:00 PM	Copper	0.134 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
0325-4328-10	3/27/2025 7:18:00 AM 3rd Floor Boys Room Left Sink #1	4/1/2025 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
0325-4328-10	3/27/2025 7:18:00 AM 3rd Floor Boys Room Left Sink #1	4/4/2025 1:56:00 PM	Copper	0.0850 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
0325-4328-11	3/27/2025 7:19:00 AM 3rd Floor Boys Room Sink #2	4/1/2025 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
0325-4328-11	3/27/2025 7:19:00 AM 3rd Floor Boys Room Sink #2	4/4/2025 1:56:00 PM	Copper	0.107 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
0325-4328-12	3/27/2025 7:20:00 AM 3rd Floor Boys Room Sink #3	4/1/2025 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
0325-4328-12	3/27/2025 7:20:00 AM 3rd Floor Boys Room Sink #3	4/4/2025 1:56:00 PM	Copper	0.0970 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
0325-4328-13	3/27/2025 7:21:00 AM 3rd Floor Boys Room Sink #4	4/1/2025 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
0325-4328-13	3/27/2025 7:21:00 AM 3rd Floor Boys Room Sink #4	4/4/2025 1:56:00 PM	Copper	0.0870 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
0325-4328-14	3/27/2025 7:22:00 AM 3rd Floor Boys Room Sink #5	4/1/2025 9:11:00 AM	Lead (1st Draw)	6.26 ug/L	15 ug/L 2 ug/l	Std Method 3113B
0325-4328-14	3/27/2025 7:22:00 AM 3rd Floor Boys Room Sink #5	4/4/2025 1:56:00 PM	Copper	0.138 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
0325-4328-15	3/27/2025 7:23:00 AM 3rd Floor Girls Room Left Sink #1	4/1/2025 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
0325-4328-15	3/27/2025 7:23:00 AM 3rd Floor Girls Room Left Sink #1	4/4/2025 1:56:00 PM	Copper	0.113 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
0325-4328-16	3/27/2025 7:24:00 AM 3rd Floor Girls Room Sink #2	4/1/2025 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B

# MCL - Maximum Contaminant Level

ND - Not Detected

\* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

\*\* If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Wednesday, April 9, 2025

NJDEP Laboratory Certification # 14006

Page 1 of 3



RAdata, LLC  
 27 Ironia Road, Unit 2  
 Flanders, NJ 07836  
 973-927-7303 Phone  
 973-927-4980 Fax

**Customer:** Felician School  
 260 South Main Street  
 Lodi, NJ 076440000

## Laboratory Results

Sample Number	Sample Location	Collected By
0325-4328	260 South Main Street - Lodi Boro	Ken, Waldele

  

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0325-4328-16	3/27/2025 7:24:00 AM 3rd Floor Girls Room Sink #2	4/4/2025 1:56:00 PM	Copper	0.0980 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
0325-4328-17	3/27/2025 7:25:00 AM 3rd Floor Girls Room Sink #3	4/1/2025 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
0325-4328-17	3/27/2025 7:25:00 AM 3rd Floor Girls Room Sink #3	4/4/2025 1:56:00 PM	Copper	0.0700 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
0325-4328-18	3/27/2025 7:26:00 AM 3rd Floor Girls Room Sink #4	4/1/2025 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
0325-4328-18	3/27/2025 7:26:00 AM 3rd Floor Girls Room Sink #4	4/4/2025 1:56:00 PM	Copper	0.0540 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
0325-4328-19	3/27/2025 7:27:00 AM 3rd Floor Girls Room Sink #5	4/1/2025 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
0325-4328-19	3/27/2025 7:27:00 AM 3rd Floor Girls Room Sink #5	4/4/2025 1:56:00 PM	Copper	< 0.0500 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
0325-4328-2	3/27/2025 7:39:00 AM Ground Floor Girls Room Left Sink	4/1/2025 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
0325-4328-2	3/27/2025 7:39:00 AM Ground Floor Girls Room Left Sink	4/4/2025 1:56:00 PM	Copper	0.114 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
0325-4328-3	3/27/2025 7:40:00 AM Ground Floor Girls Room Right Sink	4/1/2025 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
0325-4328-3	3/27/2025 7:40:00 AM Ground Floor Girls Room Right Sink	4/4/2025 1:56:00 PM	Copper	0.146 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
0325-4328-4	3/27/2025 7:35:00 AM 1st Floor Student Bathroom Left Sink	4/1/2025 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
0325-4328-4	3/27/2025 7:35:00 AM 1st Floor Student Bathroom Left Sink	4/4/2025 1:56:00 PM	Copper	0.100 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
0325-4328-5	3/27/2025 7:36:00 AM 1st Floor Student Bathroom Right Sink	4/1/2025 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
0325-4328-5	3/27/2025 7:36:00 AM 1st Floor Student Bathroom Right Sink	4/4/2025 1:56:00 PM	Copper	0.0740 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B

# MCL - Maximum Contaminant Level

ND - Not Detected

\* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

\*\* If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.

Wednesday, April 9, 2025

NJDEP Laboratory Certification # 14006

Page 2 of 3



RAdata, LLC  
 27 Ironia Road, Unit 2  
 Flanders, NJ 07836  
 973-927-7303 Phone  
 973-927-4980 Fax

**Customer:** Felician School  
 260 South Main Street  
 Lodi, NJ 076440000

## Laboratory Results

Sample Number	Sample Location	Collected By
0325-4328	260 South Main Street - Lodi Boro	Ken, Waldele

  

Sample No.	Collected	Analyzed	Parameter	Result	MCL #	Method
0325-4328-6	3/27/2025 7:28:00 AM 2nd Floor Boys Room Left Sink #1	4/1/2025 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
0325-4328-6	3/27/2025 7:28:00 AM 2nd Floor Boys Room Left Sink #1	4/4/2025 1:56:00 PM	Copper	0.107 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
0325-4328-7	3/27/2025 7:29:00 AM 2nd Floor Boys Room Sink #2	4/1/2025 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
0325-4328-7	3/27/2025 7:29:00 AM 2nd Floor Boys Room Sink #2	4/4/2025 1:56:00 PM	Copper	0.0860 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
0325-4328-8	3/27/2025 7:30:00 AM 2nd Floor Boys Room Sink #3	4/1/2025 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
0325-4328-8	3/27/2025 7:30:00 AM 2nd Floor Boys Room Sink #3	4/4/2025 1:56:00 PM	Copper	0.0960 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B
0325-4328-9	3/27/2025 7:31:00 AM 2nd Floor Boys Room Sink #4	4/1/2025 9:11:00 AM	Lead (1st Draw)	< 2.00 ug/L	15 ug/L 2 ug/l	Std Method 3113B
0325-4328-9	3/27/2025 7:31:00 AM 2nd Floor Boys Room Sink #4	4/4/2025 1:56:00 PM	Copper	0.0940 mg/L	1.3 mg/L 0.05 mg/l	Std Method 3111B

**The parameters tested on this report PASSED NJ  
 Drinking Water Standards.**

*This report represents results associated to the point of collection location in the structure only. It is recommended that other locations within the structure where water can be consumed, be tested to verify compliance to state and federal drinking water regulations.*

Reviewed and Approved by:

**Kaity March, Laboratory Manager Designe**

# MCL - Maximum Contaminant Level

ND - Not Detected

\* At the time of sampling this parameter does not meet NJDEP Standards for drinking water.

\*\* If the initial Gross alpha particle count exceeds 5 pCi/l a second count is required according to the Method. The MCL for gross alpha particle activity is 15 pCi/l.